



PHILIPPINE HEART CENTER
East Avenue, Quezon City

SUPPLEMENTAL BID BULLETIN No. 012-2022

SUBJECT : Revisions in the Bidding Document

PROJECT/S : 1 Lot Supply and Materials for the Replacement of Existing Steel Framed Glass Window to Aluminum/PVC Framed Glass Windows Along the 2nd Floor Peripheral Corridor of the Hospital Building - ITB No. 003.22


To ensure that the transactions are comparatively advantageous to the interests of the PHC, the originally pre-issued Abstract of Sealed Bidding as mentioned above, revisions/changes are hereby introduced.


Item No./ Page No.	PHC – Technical Specifications FROM	Clarifications/Modifications (Should be read as) TO
1.2 Page 1	Temporary Facilities	Temporary Facilities This includes board-ups to separate working area from hospital premises, safety covers to protect people below, scaffolding and temporary covers on window openings for protection from rain. This also includes temporary storage of window material.
Page 2	Concrete Window Sill Detail	- see attached drawing/layout for reference
Page 3	For Waterproofing	Elastomeric type is added to waterproofing list (cementitious, membrane, hot applied). THAT IS NOT ACCEPTED as these has failed based on previous experience.

This Supplemental Bid Bulletin is hereby issued to modify the original parameters as stated therein. All other requirements previously stated on the bid documents must be complied.


Please be guided accordingly.

Approved. Done this 26th day of January 2022, PHC.


RANULFO B. JAVELOSA, JR., MD.
Chairman, BAC for Infra, Med Supplies & Services


ARCH'T. MARLON L. REYES
Architect III, Bldg. & Facilities Section
Engineering & Maintenance Div.

DETAIL SECTION



INTERIOR WALL TOP FRANK &
WATERPROOFING.

ARCH'T. MARLON L. REYES
Architect III, Bldg. & Facilities Section
Engineering & Maintenance Div.